

COMPRESSOR DATA SHEET

Rotary Screw Compressor

MODEL DATA - FOR COMPRESSED AIR			
1	Manufacturer: Sullair Corp		
2	Model Number: TS20-150LWC Air-cooled ☒ Water-cooled ☒ Oil-injected Oil-free	# of Stages: 2 VALUE UNIT	
3	Rated Capacity at Full Load Operating Pressure ^{a, f}	826	acfm ^{a, f}
4	Full Load Operating Pressure ^b	100	psig ^b
5	Maximum Full Flow Operating Pressure ^c	100	psig ^c
6	Drive Motor Nameplate Rating	150	hp
7	Drive Motor Nameplate Nominal Efficiency	95.8	percent
8	Fan Motor Nameplate Rating (if applicable)	-	hp
9	Fan Motor Nameplate Nominal Efficiency	-	percent
10	Total Package Input Power at Zero Flow ^e	33.8	kW ^e
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure ^d	135.3	kW ^d
12	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure ^g	16.38	kW/100 cfm ^g

NOTES:

- Measured at the discharge terminal point of the compressor package in accordance with the CAGI/PNEUROP PN2CPTC2 Test Code (Annex C to ISO 1217). ACFM is actual cubic feet per minute at inlet conditions.
- The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 10) were measured for this data sheet.
- Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- Total package input power at other than reported operating points will vary with control strategy.
- Tolerance is specified in the CAGI/PNEUROP PN2CPTC2 Test Code (Annex C to ISO 1217)
- Tolerance is specified in the CAGI/PNEUROP PN2CPTC2 Test Code (Annex C to ISO 1217) as follows:

Volume Flow Rate at specified conditions		Volume Flow Rate ^f	Specific Energy Consumption ^g
<u>m³ / min</u>	<u>ft³ / min</u>	%	%
Below 0.5	Below 15	+/- 7	+/- 8
0.5 to 1.5	15 to 50	+/- 6	+/- 7
1.5 to 15	50 to 500	+/- 5	+/- 6
Above 15	Above 500	+/- 4	+/- 5

Member



This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.